

ಕರ್ನಾಟಕ ವಿಧಾನ ಪರಿಷತ್ತು

ಚುಕ್ಕೆ ಗುರುತಿಲ್ಲದ ಪ್ರಶ್ನೆ ಸಂಖ್ಯೆ : **1060**
 ಸದಸ್ಯರ ಹೆಸರು : ಡಾ: ಯತೀಂದ್ರ ಎಸ್ (ವಿಧಾನಸಭಾ ಕ್ಷೇತ್ರ)
 ಉತ್ತರಿಸುವ ದಿನಾಂಕ : **16-12-2025**
 ಉತ್ತರಿಸುವ ಸಚಿವರು : ಮಾನ್ಯ ಸಣ್ಣ ಕ್ಷೇತ್ರದ ಹಾಗೂ ಸಾರ್ವಜನಿಕ ವಲಯ
 ಉದ್ದೇಶಗಳ ಸಚಿವರು

ಕ್ರ. ಸಂ.	ಪ್ರಶ್ನೆಗಳು	ಉತ್ತರ
(ಅ)	<p>ರಾಜ್ಯದ ಗ್ರಾಮೀಣ ಭಾಗದಲ್ಲಿ ಸಣ್ಣ ಕ್ಷೇತ್ರದ ಹಾಗೂ ಭಾಗದಲ್ಲಿ ಸಾಫ್ಟ್‌ವರ್‌ಯಾಗುತ್ತಿದ್ದು, ಸ್ವಂತ ಬುಚ್ಚನಲ್ಲಿ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಪಡೆಯಲು DISCOMS ಸೂಚಿಸುತ್ತಿರುವದರಿಂದ ಸಣ್ಣ ಕ್ಷೇತ್ರದ ಸಾಫ್ಟ್‌ವರ್ ಹಿನ್ನಡೆಯಾಗುತ್ತಿರುವುದು ಸರ್ಕಾರದ ಗಮನಕ್ಕೆ ಬಂದಿದೆಯೇ; ಬಂದಿದ್ದಲ್ಲಿ ಸದರಿ ಸಮಸ್ಯೆಗಳನ್ನು ಪರಿಹರಿಸಲು ಕೇಗೊಂಡ ಕ್ರಮಗಳೇನು? (ವಿವರ ಒದಗಿಸುವುದು)</p>	<p>ವಿದ್ಯುತ್ ಸರ್ಬರಾಜು ಕಂಪನಿಗಳಲ್ಲಿ ಸಾಮಾನ್ಯವಾಗಿ ಸಣ್ಣ ಮತ್ತು ಮದ್ಯಮ ಕ್ಷೇತ್ರದಲ್ಲಿ ಜಕಾತಿ ಅಡಿಯಲ್ಲಿ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಾಗಿ ಅರ್ಜಿ ಸಲ್ಲಿಸಿದ್ದಲ್ಲಿ, ವಿದ್ಯುತ್ಕಷ್ಟ ಸರ್ಬರಾಜಿನ ಷರತ್ತು 7.00 ಮತ್ತು ಅದರ ಉಪನಿಯಮಗಳ ಅನುಸಾರ 150 KW/201 HP ವರೆಗೆ ಪ್ರತಿ ಸಾಫ್ಟ್‌ವರ್ ಕ್ಷೇತ್ರದಲ್ಲಿ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸಲಾಗುತ್ತಿದೆ. ಅರ್ಜಿದಾರರು ತಮ್ಮ ಆಯ್ದುಯ ಮೇರೆಗೆ ಕೆಳಗಿನ ಎರಡರಲ್ಲಿ ಯಾವುದಾದರೂ ಒಂದು ಯೋಜನೆಯನ್ನು ವಿದ್ಯುತ್ ಮೂಲಸೌಕರ್ಯಗಳನ್ನು ಅಭಿವೃದ್ಧಿಪಡಿಸಲು ಆಯ್ದು ಮಾಡಬಹುದಾಗಿದೆ,</p> <p>1. ಶೈವಣಿ ವಂತಿಗೆ ಯೋಜನೆ (Department Execution Work): ಈ ಯೋಜನೆಯಡಿಯಲ್ಲಿ, ಕೆ.ಇ.ಆರ್.ಸಿ ವಿದ್ಯುತ್ ಸರ್ಬರಾಜಿಗಾಗಿ ವಚ್ಚೆದ ವಸೂಲಿ (RoE) ನಿಯಮ 3.1.1(B)ರಲ್ಲಿ ನಿಗದಿಪಡಿಸಿರುವ ಶುಲ್ಕಗಳನ್ನು ಅರ್ಜಿದಾರರಿಂದ ಸಂಗ್ರಹಿಸಿ, ಎಸಾಗಂಗಳ ವತ್ತಿಯಿಂದ ಹೊಸ ವಿದ್ಯುತ್ ಮೂಲಸೌಕರ್ಯಗಳನ್ನು ಅಭಿವೃದ್ಧಿಪಡಿಸಿ ಅಥವಾ ಅಸ್ತಿತ್ವದಲ್ಲಿರುವ ವಿದ್ಯುತ್ ಮೂಲಸೌಕರ್ಯಗಳನ್ನು ವಿಸ್ತರಿಸುವ/ವೃದ್ಧಿಸುವ (augmentation) ಮೂಲಕ, ಕ್ಷೇತ್ರದ ಸಾಫ್ಟ್‌ವರಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕವನ್ನು ಕಲ್ಪಿಸಲಾಗುವುದು.</p> <p>2. ಸ್ವಯಂ ಕಾರ್ಯನಿರ್ವಹಣಾ ಯೋಜನೆ (Self-Execution Work): ಈ ಯೋಜನೆಯಡಿ, ಅರ್ಜಿದಾರರು ತಮ್ಮ ಆಯ್ದುಯ ಅರ್ಹ ಹಾಗೂ ಮಾನ್ಯ ಪರವಾನಗಿ/ಲ್ಯಾಸೆನ್ಸ್ ಹೊಂದಿರುವ ವಿದ್ಯುತ್ ಗುತ್ತಿಗೆದಾರರ ಮೂಲಕ ಕಾಮಗಾರಿಯನ್ನು ನಿರ್ವಹಿಸಬಹುದಾಗಿದೆ. ಇಂತಹ ಸಂದರ್ಭಗಳಲ್ಲಿ, RoE ನಿಯಮ 3.1.1(B) ರಲ್ಲಿ ನಿಗದಿಪಡಿಸಿರುವ ಶುಲ್ಕಗಳನ್ನು ಪಾವತಿಸುವ ಅಗತ್ಯವಿರುವುದಿಲ್ಲ.</p>

		<p>ಕೆ.ಇ.ಆರ್.ಸಿ ವಿದ್ಯುಚ್ಚೈ ಸರಬರಾಜಿನ ಪರತ್ತು 7.00 ಮತ್ತು ಅದರ ಉಪನಿಯಮಗಳ ಹಾಗೂ ಕೆ.ಇ.ಆರ್.ಸಿ ವಿದ್ಯುತ್ ಸರಬರಾಜಿಗಾಗಿ ವೆಚ್ಚದ ವಸೂಲಿ (RoE) ನಿಯಮ 3.1.1(B)ರನ್ನು ಅನುಬಂಧದಲ್ಲಿ ಒದಗಿಸಲಾಗಿದೆ.</p> <p>ಇದಲ್ಲದೆ, ದೊಡ್ಡ ಕ್ಷೇತ್ರಕ್ಕೆ ಹೆಚ್ಚಿನ ಜಕಾತಿ ಅಡಿಯಲ್ಲಿ ವಿದ್ಯುತ್ ಸಂಪರ್ಕಕ್ಕಾಗಿ ಅರ್ಜಿ ಸಲ್ಲಿಸಿದ್ದಲ್ಲಿ ವಿದ್ಯುಚ್ಚೈ ಸರಬರಾಜಿನ ಪರತ್ತು 8.00 ಮತ್ತು ಅದರ ಉಪನಿಯಮಗಳ ಅನುಸಾರ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸಲಾಗುತ್ತಿದೆ. ಇದಕ್ಕಾಗಿ ಅರ್ಜಿದಾರರು ಸ್ವಯಂ ಕಾಮಗಾರಿ ಯೋಜನೆಯಲ್ಲಿ ಅಗತ್ಯಾಲಿರುವ ಮೂಲಸೌಕರ್ಯವನ್ನು ಅಭಿವೃದ್ಧಿಪಡಿಸಿಕೊಳ್ಳಬೇಕು ಮತ್ತು ಅರ್ಜಿದಾರರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿಗಳಿಗೆ ಯಾವುದೇ ಮೂಲಸೌಕರ್ಯದ ವೆಚ್ಚವನ್ನು ಪಾವತಿಸುವಂತಿರುವುದಿಲ್ಲ.</p>
--	--	---

ಸಿಇ 163 ಎಸ್‌ಎಸ್‌ಎಂ 2025


(ಶರಣಬಸಪ್ಪ ದರ್ಶನಾಪೂರ)
 ಸಣ್ಣ ಕ್ಷೇತ್ರಕ್ಕೆ ಮತ್ತು ಸಾರ್ವಜನಿಕ ಉದ್ದಿಮೆಗಳ ಸಚಿವರು.

7.00 APPLICABLE TO LT INDUSTRIAL AND COMMERCIAL POWER INSTALLATIONS
(Other than those covered under Clause s 5,6,9,10 &11)

7.01 General procedure for arranging power supply under Clause 4.00 and provisions under K.E.R.C. (Recovery of Expenditure for Supply of Electricity) Regulations, 2004 and its amendments from time to time, {Annex-2} wherever applicable shall be complied with by the Applicant and the Licensee.

7.02 The application shall be registered at the subdivision office of the Licensee.

7.03 Amended version vide Notification No. K.E.R.C./COS/D/2/17-18 Dated: 27.12.2017 published In Karnataka Gazette dated: 28.12.2017

For industrial layouts developed, Including the residential buildings constructed for the use of entrepreneurs, as part of Industrial area. by the KIADB/KSSIDC/ KEONICS/ Others, the entire work of 11 kV line/ UG Cable, LT line /UG cable transformers etc.. shall be carried out on self-execution basis by the applicant as per the estimate prepared by the licensee. Supervision charges at 10% on the cost of estimate excluding employees cost and MSD shall be payable subject to a maximum of Rs. 15 lakhs. In such cases, maintenance charges of five (5%) per cent on the total cost of the estimate and recovery of expenditure for supply of electricity as per the KERC (Recovery of Expenditure for Supply of Electricity) Regulations. 2004 and its amendments from time to time, shall not be collected.

L.T. Trivector Meter with demand indicator shall be provided at the option of the Consumer to avail "Demand based Tariff". In such cases, fixed charges shall be levied on the basis of the sanctioned load or M.D. recorded whichever is higher irrespective of the connected load as long as the LT Trivector meter is maintained in good working condition and not tampered with. If the recorded M.D. is higher than the sanctioned load, penal charges shall apply as per Clause 42.01 of these Conditions.

7.05 T.O.D. Tariff facility shall be extended to any Consumer at his option for eligible categories.

7.06 The LT industrial consumer desirous of letting out a part of his premises shall be permitted to allow his tenant to use the power at the same tariff as applicable to the said consumer and to collect the charges for the power from such tenant on no profit no loss basis (i.e.. sharing of electricity bill), through a sub-meter as approved by the licensee and such arrangement

shall not be treated as unauthorized extension of supply or resale of electricity.

Provided that for billing, the consumption recorded in the main meter shall be reckoned as per the slab rates in accordance with the Tariff Order in force.

Clause 3.1.1(B) RoE is as follows,

For loads less than 50 KW in respect of industrial installations:		
Sl. No.	Requisitioned Load	Recoverable amount
i	Up to and inclusive of 3KW	NIL
ii.	Above 3 KW and up to and inclusive of 15 KW	Rs. 650 per KW for loads above 3 KW
iii.	Above 15 KW and Up to and inclusive of 25 KW	Rs. 7800 plus Rs.1300 per KW for loads above 15 KW
iv	25 KW and up to and inclusive of 50 KW.	Rs. 20800 plus Rs.1950 per KW for loads above 25 KW
v	Above 50 kW up to and inclusive of 150 kW.	Rs. 8000 per kW wherever UG/AB cable is applicable & Rs. 5800 per kW wherever OH lines are applicable for the entire requisition Load.

- a) Fraction of KW shall be rounded off to next higher KW.
- b) In case of industrial load, the maximum requisitioned load shall be less than, up to and inclusive of 150 KW.
- c) In addition to the above charges an additional amount of Rs.1000/kW for loads above 3 KWs shall be collected in Bangalore Metropolitan Area comprising of Bangalore Mahanagara Palike, Dasarahalli City Municipal Council, Yelahanka City Municipal Council, Byatarayanapura City Municipal Council, Kengeri Town Municipal Council, Rajarajeshwari City Municipal Council, Krishnarajapura City Municipal Council, Mahadevapura City Municipal Council, Bommanahalli City Municipal Council and BDA Areas towards HT/LT UG cable /ABC system. However, these charges are not applicable for installations seeking power supply for loads above 35 kW in respect of domestic, commercial and mixed load installations & loads 50 kW & above in respect of Industrial installations.
- d) The above charges shall not be applicable to streetlights, LT water supply and IP sets that are covered under separate provisions in these regulations.
- e) Where additional loads are requisitioned for existing installations, the cost towards electric line/plant shall be collected for the additional load only at the appropriate slab rate. The slab rate shall be arrived at based on the total load (existing + additional load).
- f) The additional amount of Rs.1000/- per KW applicable for Bangalore Metropolitan Area comprising of Bangalore Mahanagara Palike, Dasarahalli City Municipal Council, Yelahanka City Municipal Council, Byatarayanapura City Municipal Council, Kengeri Town Municipal Council, Rajarajeshwari City Municipal Council, Krishnarajapura City Municipal Council, Mahadevapura City Municipal Council, Bommanahalli City Municipal Council and BDA Areas.

towards HT/LT UG cable /ABC system shall be collected in case of existing installations for the additional load sought for.