



ಕರ್ನಾಟಕ ವಿಧಾನ ಪರಿಷತ್ತು


ಚುಕ್ಕೆ ಗುರುತಿಲ್ಲದ ಪ್ರಶ್ನೆ ಸಂಖ್ಯೆ : 765 (888)
 ಸದಸ್ಯರ ಹೆಸರು : ಶ್ರೀ ಮಂಜುನಾಥ ಭಂಡಾರಿ
 (ಸ್ಥಳೀಯ ಸಂಸ್ಥೆಗಳ ಕ್ಷೇತ್ರ)
 ಉತ್ತರಿಸಬೇಕಾದ ದಿನಾಂಕ : 19.08.2025
 ಉತ್ತರಿಸಬೇಕಾದ ಸಚಿವರು : ನಗರಾಭಿವೃದ್ಧಿ ಸಚಿವರು

ಪ್ರಶ್ನೆ	ಉತ್ತರ
ಅ) ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ಕುಡಿಯುವ ನೀರು ಸ್ವಚ್ಛವಾಗಿರುವ ಕುರಿತು ಹೇಗೆ ಖಾತರಿ ಪಡಿಸಲಾಗುತ್ತಿದೆ ಎಷ್ಟು ಅವಧಿಗೊಮ್ಮೆ ಕುಡಿಯುವ ನೀರನ್ನು ಜಲ ಸ್ಥಾವರ ಮತ್ತು ಪೂರೈಕೆಯ ಕೊನೆ ಹಂತದಿಂದ ಸಂಗ್ರಹಿಸಿ ಪರೀಕ್ಷಿಸಲಾಗುತ್ತಿದೆ; (ಇತ್ತೀಚಿನ 3 ವರ್ಷಗಳ ವರದಿ ನೀಡುವುದು)	ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿನ ತುಂಬೆ ನೀರು ಶುದ್ಧೀಕರಣ ಘಟಕದಲ್ಲಿರುವ ಪ್ರಯೋಗಾಲಯದಲ್ಲಿ ಕೇಂದ್ರ ಆರೋಗ್ಯ ಮತ್ತು ಪರಿಸರ ಇಂಜಿನಿಯರಿಂಗ್ (CPHEEO) ಮಾರ್ಗಸೂಚಿಯಂತೆ ಪ್ರತಿದಿನ Turbidity, Odour, Taste, PH Chlorides, Alkalinity Total hardness, Calcium, Magnesium Residual free chlorine, Total Dissolved solids ಪ್ರತಿವಾರ Total Coliform Faecal coliform Iron Fluorides Nitrate Sulphate ಹಾಗೂ ಪ್ರತಿ ತಿಂಗಳು Aluminium Copper Zinc Sulphide Arsenic ಪರೀಕ್ಷೆಗಳನ್ನು ನಡೆಸಿ ವರದಿಗಳಲ್ಲಿ ದಾಖಲಿಸಲಾಗುತ್ತಿದೆ. ಇದಲ್ಲದೆ ಮಂಗಳೂರಿನ ಬೆಂದೂರ್‌ವೆಲ್ ನೀರು ಶುದ್ಧೀಕರಣ ಘಟಕದಲ್ಲಿ ದಿನಾಂಕ 03.08.2023 ರಿಂದ ನೂತನ ಪ್ರಯೋಗಾಲಯ ಅಭಿವೃದ್ಧಿಪಡಿಸಿದ್ದು, ಈ ಪ್ರಯೋಗಾಲಯದಲ್ಲಿ CPHEEO ಮಾರ್ಗಸೂಚಿ ಅನುಸಾರ ನೀರಿನ ಗುಣಮಟ್ಟ ಪರೀಕ್ಷಿಸಿ, ವರದಿ ದಾಖಲಿಸಲಾಗುತ್ತಿದೆ. ನೇತ್ರಾವತಿ ನದಿ ನೀರು ಸೇರಿದಂತೆ ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯ ವಿವಿಧ ಪಂಪ್‌ಹೌಸ್‌ಗಳು ಹಾಗೂ ಪ್ರತಿ ಹದಿನೈದು ದಿನಗಳಿಗೊಮ್ಮೆ 60 ವಾರ್ಡ್‌ಗಳ ಆಯ್ಕೆ ಪ್ರದೇಶಗಳಲ್ಲಿ ಮಂಗಳೂರಿನ ಸರ್ಕಾರಿ ಮೀನುಗಾರಿಕಾ ಕಾಲೇಜಿನ ಪ್ರಯೋಗಾಲಯದಲ್ಲಿ (total coliform, faecal coliform) ಗುಣಮಟ್ಟ ಪರೀಕ್ಷಿಸಿ ವರದಿ ದಾಖಲಿಸಲಾಗುತ್ತದೆ. ರಾಜ್ಯದ ನಗರ ಸ್ಥಳೀಯ ಸಂಸ್ಥೆಗಳ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ಸಾರ್ವಜನಿಕರಿಗೆ ಸರಬರಾಜು ಮಾಡುತ್ತಿರುವ ಕುಡಿಯುವ ನೀರನ್ನು ಕಾಲಕಾಲಕ್ಕೆ NABL Accredited ಲ್ಯಾಬ್‌ಗಳಲ್ಲಿ ಪರೀಕ್ಷಿಸಿ ಶುದ್ಧ ಹಾಗೂ ಸುರಕ್ಷಿತ ಕುಡಿಯುವ ನೀರನ್ನು ಪೂರೈಸುವ ಕುರಿತು ಪೌರಾಡಳಿತ ನಿರ್ದೇಶನಾಲಯದಿಂದ ಸುತ್ತೋಲೆಯನ್ನು ಹೊರಡಿಸಲಾಗಿದ್ದು, ಅದರ ಪ್ರತಿಯನ್ನು ಅನುಬಂಧ-1 ರಲ್ಲಿ ನೀಡಲಾಗಿದೆ. ಆಯುಕ್ತರು, ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ ರವರು ಸಲ್ಲಿಸಿರುವ ಕುಡಿಯುವ ನೀರಿನ ಇತ್ತೀಚಿನ 3 ವರ್ಷಗಳ ಪರೀಕ್ಷಾ ವರದಿಯನ್ನು ಅನುಬಂಧ-2 ರಲ್ಲಿ ನೀಡಲಾಗಿದೆ.

ಆ)	ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ಕುಡಿಯುವ ನೀರನ್ನು ಸಂಗ್ರಹಿಸುವ ಜಲ ಸ್ತಾವರಗಳನ್ನು ಎಷ್ಟು ಅವಧಿಗೊಮ್ಮೆ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ; ಯಾವ ವಿಧಾನಗಳ ಮೂಲ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ;	ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ಬರುವ ಎಲ್ಲಾ ಜಲಸಂಗ್ರಹಗಳನ್ನು ವರ್ಷಕ್ಕೊಮ್ಮೆ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ. ಸದರಿ ಎಲ್ಲಾ ನೀರು ಸರಬರಾಜು ಜಲಸಂಗ್ರಹಗಳನ್ನು ಮತ್ತು ಜಲ ಸ್ತಾವರಗಳಲ್ಲಿ ತುಂಬಿರುವ ಹೂಳುಗಳನ್ನು Manual ಮೂಲಕ ಸ್ವಚ್ಛಗೊಳಿಸಿ, ಸದರಿ ಸಂಗ್ರಹಗಳಿಗೆ ಸೋಂಕು ನಿವಾರಣೆಗಳನ್ನು ಸಿಂಪಡಿಸಿ, ಸ್ವಚ್ಛ ನೀರಿನಲ್ಲಿ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ.
ಇ)	ಮಹಾನಗರ ಪಾಲಿಕೆಯ ಸ್ವಂತ ಕಟ್ಟಡಗಳಲ್ಲಿ ಕುಡಿಯುವ ನೀರನ್ನು ಸಂಗ್ರಹಿಸುವ ನೀರಿನ ಟ್ಯಾಂಕುಗಳನ್ನು ಎಷ್ಟು ಅವಧಿಗೊಮ್ಮೆ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ; ಯಾವ ವಿಧಾನಗಳ ಮೂಲಕ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ ಹಾಗೂ ಕಡೆಯ ಬಾರಿ ಯಾವಾಗ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗಿದೆ;	ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆಯ ಸ್ವಂತ ಕಟ್ಟಡಗಳಲ್ಲಿ ಕುಡಿಯುವ ನೀರನ್ನು ಸಂಗ್ರಹಿಸುವ ನೀರಿನ ಟ್ಯಾಂಕುಗಳನ್ನು 6 ತಿಂಗಳಿಗೊಮ್ಮೆ ಪ್ರೈವೇಟ್ ವಾಶ್ ಮೂಲಕ ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗುತ್ತಿದೆ ಹಾಗೂ ಕಡೆಯ ಬಾರಿ ದಿನಾಂಕ: 16.06.2025 ರಂದು ಸ್ವಚ್ಛಗೊಳಿಸಲಾಗಿದೆ.
ಈ)	ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ಕೊಳಚೆ ನೀರನ್ನು ಎಸ್ ಡಿ ಪಿ ಟಿ ಮೂಲಕ ಸರಿಯಾದ ಸಂಸ್ಕರಣೆ ಇಲ್ಲದೆ ತೆರೆದ ಹಳ್ಳದ ಮೂಲಕ ಹರಿಯುತ್ತಿರುವುದನ್ನು ಮತ್ತು ಮ್ಯಾನ್‌ಹೋಲ್ ತೆರೆದು ರಸ್ತೆಯಲ್ಲಿ ಹರಿಯುವುದನ್ನು ತಡೆಯಲು ವಹಿಸಲಾಗಿರುವ ಕ್ರಮವೇನು?	ಮಂಗಳೂರು ಮಹಾನಗರಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ ಒಟ್ಟು 4 STP ಗಳು ಕಾರ್ಯ ನಿರ್ವಹಿಸುತ್ತಿದ್ದು, ಸದರಿ STP ಗಳಲ್ಲಿ ಸಂಸ್ಕರಿಸಿದ ನೀರನ್ನು ನೇತ್ರಾವತಿ, ಗುರುಪುರ ಮತ್ತು ನಂದಿನಿ ನದಿಗೆ ರಾಜಕಾಲುವೆಯ ಮೂಲಕ ಬಿಡಲಾಗುತ್ತಿದೆ. ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ 64 MLD ಯಷ್ಟು ತ್ಯಾಜ್ಯ ನೀರು ಉತ್ಪತ್ತಿ ಆಗುತ್ತಿದ್ದು, ಪಾಲಿಕೆಯಲ್ಲಿ ಒಟ್ಟು 88.75 MLD ಸಾಮರ್ಥ್ಯದ STP ಘಟಕಗಳಿರುತ್ತದೆ. ಅದರಲ್ಲಿ, ಪ್ರಸ್ತುತ 53.5 MLD ತ್ಯಾಜ್ಯ ನೀರನ್ನು ಸಂಸ್ಕರಿಸಲಾಗುತ್ತಿರುತ್ತದೆ. ವಿವರಗಳು ಈ ಕೆಳಗಿನಂತಿವೆ: 1. ಕಾವೂರು STP ಯ ಸಾಮರ್ಥ್ಯವು 43.5 MLD ಗಳಾಗಿದ್ದು ಪ್ರಸ್ತುತ 30 MLD ಗಳಷ್ಟು ಜಲತ್ಯಾಜ್ಯವು STP ಗೆ ಬರುತ್ತಿದೆ. ಸದರಿ STP ಯಿಂದ ಸಂಸ್ಕರಿಸಿದ ನೀರನ್ನು ಮಂಗಳೂರು Special Economic Zone ರವರು ಅಳವಡಿಸಿದ TTP ಯಲ್ಲಿ (Tertiary Treatment Plant) ಪುನಃ ಸಂಸ್ಕರಿಸಿ ಸಂಪೂರ್ಣವಾಗಿ ಕಾರ್ಖಾನೆಗೆ ಸರಬರಾಜು ಮಾಡಲಾಗುತ್ತಿದೆ. ಸದರಿ STP ಯಲ್ಲಿ TTP ಯನ್ನು ಅಳವಡಿಸಿದ್ದು ಸಂಸ್ಕರಿಸಿದ ಬಳಸಿದ ನೀರನ್ನು ಸಂಪೂರ್ಣವಾಗಿ ಕಾರ್ಖಾನೆಗಳಿಗೆ ಸರಬರಾಜು ಮಾಡಲಾಗುತ್ತಿದೆ. ಸದರಿ STP ಯಲ್ಲಿ 13.5 MLD ಗ್ಯಾಪ್ ಇರುತ್ತದೆ. 2. ಪಚ್ಚನಾಡಿ STP ಯ ಸಾಮರ್ಥ್ಯವು 8.75 MLD ಗಳಾಗಿದ್ದು, ಪ್ರಸ್ತುತ 7.5 MLD ಗಳಷ್ಟು ಜಲತ್ಯಾಜ್ಯವು STP ಗೆ ಬರುತ್ತಿದೆ. ಈ STP ಯು Activated Sludge Process ತಂತ್ರಜ್ಞಾನದ ಮೂಲಕ ಕಾರ್ಯನಿರ್ವಹಿಸುತ್ತಿದ್ದು, ಇದರಲ್ಲಿ 5 MLD ನೀರನ್ನು ಸ್ಯಾಂಡ್ ಫಿಲ್ಟರ್ ತಂತ್ರಜ್ಞಾನದ TTP (Tertiary Treatment Plant) ಮೂಲಕ ಸಂಸ್ಕರಿಸಿ ಪಿಳಿಕುಳ ನಿಸರ್ಗಧಾಮ ಮತ್ತು ಗಾಲ್ಡ್

	ಕೋರ್ಟ್‌ಗೆ ಸರಬರಾಜು ಮಾಡಲಾಗುತ್ತಿದೆ. ಉಳಿದ ಸಂಸ್ಕರಿಸಿದ ನೀರನ್ನು ರಾಜಕಾಲುವೆ ಮೂಲಕ ಪಾಲ್ಕುಣಿ ನದಿಗೆ ಬಿಡಲಾಗುತ್ತಿದೆ. ಸದರಿ STP ಯಲ್ಲಿ 1.05 MLD ಗ್ಯಾಪ್ ಇರುತ್ತದೆ. 3. ಬಜಾಲ್ STP ಯ ಸಾಮರ್ಥ್ಯವು 20 MLD ಗಳಾಗಿದ್ದು ಪ್ರಸ್ತುತ 8 MLD ಗಳಷ್ಟು ಬಳಸಿದ ನೀರು STP ಗೆ ಬರುತ್ತಿದೆ. ಈ STP ಯು Activated Sludge Process ಮೂಲಕ ಕಾರ್ಯನಿರ್ವಹಿಸುತ್ತಿದ್ದು ಸಂಸ್ಕರಿಸಿದ ನೀರನ್ನು ನೇತ್ರಾವತಿ ನದಿಗೆ ಬಿಡಲಾಗುತ್ತಿದೆ. ಸದರಿ STP ಯಲ್ಲಿ 12 MLD ಗ್ಯಾಪ್ ಇರುತ್ತದೆ. 4. ಸುರತ್ಕಲ್ STP ಯ ಸಾಮರ್ಥ್ಯವು 16.5 MLD ಗಳಾಗಿದ್ದು ಪ್ರಸ್ತುತ 8 MLD ಗಳಷ್ಟು ಬಳಸಿದ ನೀರು STP ಗೆ ಬರುತ್ತಿದೆ. ಈ STP ಯು Activated Sludge Process ತಂತ್ರಜ್ಞಾನದ ಮೂಲಕ ಕಾರ್ಯನಿರ್ವಹಿಸುತ್ತಿದ್ದು, ಸಂಸ್ಕರಿಸಿದ ನೀರನ್ನು ನೇತ್ರಾವತಿ ನದಿಗೆ ಬಿಡಲಾಗುತ್ತಿದೆ. ಸದರಿ STP ಯಲ್ಲಿ 8.5 MLD ಗ್ಯಾಪ್ ಇರುತ್ತದೆ. KSPCB ನಿಯಮಾವಳಿಯಂತೆ STP ಗಳಲ್ಲಿ ಸಂಸ್ಕರಿಸಿದ ನೀರಿನ ಗುಣಮಟ್ಟವನ್ನು ಹೆಚ್ಚಿಸಲು NGT ಅನುದಾನದಲ್ಲಿ ರೂ.40.00 ಕೋಟಿಗಳ ಪ್ರಸ್ತಾವನೆಯನ್ನು ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ ವತಿಯಿಂದ ಕೆ.ಯು.ಐ.ಡಿ.ಎಫ್.ಸಿ. ರವರಿಗೆ ಸಲ್ಲಿಕೆಯಾಗಿರುತ್ತದೆ ಮತ್ತು ಜಲ್ ಹಿ ಅಮೃತ್ ಯೋಜನೆಯಡಿ ಕೈಗೊಳ್ಳಬಹುದಾದ STP ಕಾಮಗಾರಿಗಳು ಪ್ರಸ್ತುತ ವಿಸ್ತೃತ ಯೋಜನಾ ವರದಿ (DPR) ತಯಾರಿಕಾ ಹಂತದಲ್ಲಿರುತ್ತದೆ. ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿ 64 MLD ಯಷ್ಟು ತ್ಯಾಜ್ಯ ನೀರು ಉತ್ಪತ್ತಿ ಆಗುತ್ತಿದ್ದು, ಪಾಲಿಕೆಯಲ್ಲಿ ಒಟ್ಟು 88.75 MLD ಸಾಮರ್ಥ್ಯದ STP ಘಟಕಗಳಿರುತ್ತದೆ. ಅದರಲ್ಲಿ, ಪ್ರಸ್ತುತ 53.5 MLD ತ್ಯಾಜ್ಯ ನೀರನ್ನು ಸಂಸ್ಕರಿಸಲಾಗುತ್ತಿದ್ದು ಉಳಿದ 35.25 MLD ಯಷ್ಟು ಗ್ಯಾಪ್ ಇರುತ್ತದೆ. ಸದರಿ ಗ್ಯಾಪ್ ಅನ್ನು ನಿವಾರಣೆ ಮಾಡಲು ಒಳಚರಂಡಿ ರಹಿತ ಪ್ರದೇಶದಲ್ಲಿ ಒಳಚರಂಡಿ ಜಾಲವನ್ನು ಸಮಗ್ರವಾಗಿ ಅಭಿವೃದ್ಧಿ ಪಡಿಸಲು ಹಾಗೂ ಮಹಾನಗರ ಪಾಲಿಕೆ ವ್ಯಾಪ್ತಿಯಲ್ಲಿನ ಒಳಚರಂಡಿ ಜಾಲದಿಂದ ಸೋರಿಕೆ ಮತ್ತು ಕೆಂಪು ಕಲ್ಲಿನ ಮಿಶನ್ ಹೋಲ್ ಗಳನ್ನು ಮೇಲ್ದರ್ಜೆಗೇರಿಸಲು ಮಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆಯಿಂದ ರೂ.1250.00 ಕೋಟಿಗಳ ಅಂದಾಜು ಮೊತ್ತದ ಪ್ರಸ್ತಾವನೆಯನ್ನು ಪೌರಾಡಳಿತ ನಿರ್ದೇಶನಾಲಯಕ್ಕೆ ಸಲ್ಲಿಸಲಾಗಿದೆ. ಸದರಿ ಪ್ರಸ್ತಾವನೆಯನ್ನು ದಿನಾಂಕ 11.08.2024ರಂದು ಪೌರಾಡಳಿತ ನಿರ್ದೇಶನಾಲಯದಿಂದ ವ್ಯವಸ್ಥಾಪಕ ನಿರ್ದೇಶಕರು, ಕೆ.ಯು.ಐ.ಡಿ.ಎಫ್.ಸಿ. ರವರಿಗೆ ಮುಂದಿನ ಕ್ರಮಕ್ಕಾಗಿ ಸಲ್ಲಿಸಲಾಗಿದ್ದು, ಪ್ರಸ್ತಾವನೆಯು ಪರಿಶೀಲನೆಯಲ್ಲಿರುತ್ತದೆ.
--	---

ಸಂಖ್ಯೆ: ನಅಇ 57 ಎಂಎಂಸಿ 2025 (ಇ)



(ಬಿ.ಎಸ್. ಸುರೇಶ)

ನಗರಾಭಿವೃದ್ಧಿ ಹಾಗೂ ನಗರ ಯೋಜನೆ ಸಚಿವರು

ಅನುಬಂಧ 1

Basic Water Quality parameters – to be tested at source, after treatment and at random locations in the water distribution system

S. No.	Characteristic	Requirement (Acceptable Limit)	Permissible Limit in the Absence of alternate Source*	Frequency
1	pH	6.5 – 8.5	No relaxation	Daily
2	Turbidity, NTU, Max	1	5	Daily
3	Color, Hazen units, Max	5	15	Daily
4	Total Hardness, mg/L	200	600	Daily
5	Alkalinity, mg/L	200	600	Daily
6	Total dissolved solids, mg/L, Max	500	2000	Daily
7	Conductivity, μ S/cm	400	-	
8	Calcium (as Ca), mg/L, Max	75	200	Daily
9	Magnesium, mg/L	30	100	Daily
10	Chloride, mg/L	250	1000	Daily
11	Residual Aluminum, mg/L	0.03	0.2	Daily
12	Total Coliform, MPN/100 ml	2	-	Daily
13	Faecal Coliform, MPN/ 100ml	0	0	Daily
14	Iron (as Fe), mg/L, Max	0.3	No Relaxation	Daily
15	Free residual chlorine, mg/L, Min	0.2	1	Daily To be applicable only when water is chlorinated. Tested at consumer end. When protection against viral infection is required, it should be minimum 0.5 mg/L
16	Nitrate (as NO ₃), mg/L	45	-	Daily

*For the parameters where permissible limit is mentioned the same is acceptable only if alternate source of water is not available

Occasional Parameters to be tested once a year

S. No.	Characteristic	Requirement (Acceptable Limit)	Permissible Limit in the Absence of alternate Source	Frequency
1	Fluoride (as F), mg/L, Max	1.0	1.5	once a year
2	Cadmium, mg/L	0.003	-	once a year
3	Cyanide, mg/L	0.05	-	once a year
4	Lead, mg/L	0.01	-	once a year
5	Mercury, mg/L	0.001	-	once a year
6	Total Arsenic, mg/L	0.01	-	once a year
7	Total Chromium, mg/L	0.05	-	once a year

These parameters are only indicative and if in past other heavy metals or other substances such as radioactive matter, pesticides, other heavy metals etc. are tested than the same substances shall also be tested once a year as per the limits and protocols mentioned in the IS:10500 .

Frequency of Water Testing to be carried out at different locations

➤ **At the Source : (Surface Water Source & Ground Water Source):**

- **Frequency for Chemical Test:** 4 times a year at equal time intervals.
- **In case of direct pumping from Source:** frequency for chemical at least twice per year (interval should be 6 months apart from first sampling).

➤ **At water Treatment Plant: Frequency- at Inlet/Outlet Point:**

- **Chemical:** At least once per day
- **Metals:** once in a month
- **Bacteriological:** At least once per week on a pre-decided day
- **Free residual Chlorine:** (at the outlet before the distribution) if chlorination is practiced at least once per day

➤ **At water Storage (outlet of ESR/GLSR, before distribution) frequency:**

- **Chemical & Bacteriological Parameters:** at least twice per Year (interval should be 6-months apart from first sampling)
- **Free residual Chlorine (FRC):** at least once per day if chlorination is practiced.

➤ **At Water Distribution Level (at household level) Frequency:**

- **Bacteriological:** Minimum two samples per month
- **Chemical & Bacteriological Parameters:** Minimum two samples per month

ಓನುಬಂಧ-2.

2025- 2026					
Sl.No	SAMPLE NO	DATE	SAMPLE COLLECTION POINT	WARD NO	REPORT
1	1348	04.04.2025	DINKEY DINE HOTEL NEAR KADRI MATA WARD NO 32 C/O MANJUNATH J.E , SAJAN V.M	32	POTABLE
2	1350	04.04.2025	DEVI PRASAD HOUSE KADRI TEMPLE ROAD SOUTH NEAR MORE WARD NO 33 C/O MANJUNATH J.E , VARADA V.M	33	POTABLE
3	1351	04.04.2025	SHIVABAGH 1 ST CROSS,HOUSE NEAR ARUN ELECTRICAL WARD NO 34 C/O MANJUNATH J.E, VARADA V.M	34	POTABLE
4	1352	04.04.2025	ASMAS HOUSE NEAR BALA YESU CHURCH WARD NO 37, BIKARNAKATTE C/O MANJUNATH J.E , VARADA V.M	37	POTABLE
5	1353	05.04.2025	MOHAN DAS LANE DOOR NO:18-2-16/7 ATTAVARA WARD NO 40 C/O NAZEERA J.E , PRAVEEN V.M	40	POTABLE
6	1354	05.04.2025	NO:16-11-608 VICTOR JOSHWA : WARD NO 38 C/O NAZEERA J.E, PRAVEEN V.M	38	POTABLE
7	1357	07.04.2025	SHRI DEVI DOOR NO : 3-101-8 NEAR KULAI NAMMA TV OFFICE WARD NO 9 C/O LAVANYA J.E	9	POTABLE
8	1360	08.04.2025	VAMANJURU TANK WARD NO 20 C/O YATHISH J.E , NAGESH V.M	20	POTABLE
9	1361	09.04.2025	PADMAVATHI HOUSE AKASH BAVANA KAVOOR POST C/O DEEKSHA J.E WARD NO 18 , SANJAY V.M	18	POTABLE
10	1363	09.04.2025	HLPS , THUMBE	**	POTABLE
11	1364	09.04.2025	PADIL GLSR	**	POTABLE
12	1365	09.04.2025	BENDOOD INLET	**	POTABLE
13	1366	09.04.2025	BENDOOD OUTLET	**	POTABLE
14	1367	09.04.2025	KARAVALI PUMP HOUSE	**	POTABLE
15	1368	09.04.2025	MUDA PUMP HOUSE	**	POTABLE
16	1369	09.04.2025	KOTTARA JALLIGUDDE PUMPHOUSE	**	POTABLE
17	1370	09.04.2025	PANAMBURU INLET	**	POTABLE
18	1371	09.04.2025	PANAMBURU OUTLET	**	POTABLE
19	1372	09.04.2025	KULURU PUMP HOUSE	**	POTABLE
20	1373	09.04.2025	KAVOOR PUMP HOUSE	**	POTABLE
21	1374	09.04.2025	T K SUDHEER JAPPU BAPPAL 3RD CROSS WARD NO 55 C/O BHAVYA J.E, SHANTHAPPA V.M	55	POTABLE
22	1375	09.04.2025	NITHYANANDA BEKAL MACHINE COMPOUND WARD NO 56 C/O CHINMAYI J.E, YASHWANTH V. M	56	POTABLE
23	1376	09.04.2025	NAGESH KOTIAN GORAKSH DANDU JAPPU WARD NO 57 C/O BHAVYA J.E, YASHWANTH V.M	57	POTABLE
24	1377	09.04.2025	SUDHA MANI BOLAR EMPHASIS ROAD JAPPU WARD NO 58 C/O CHINMAYI J.E, YASHWANTH V.M	58	POTABLE

25	1378	09.04.2025	JOSEPH THEODORE JAPPU BAPAL 1ST CROSS WARD NO 59 C/O BHAVYA J.E, SHANTHAPPA V.M	59	POTABLE
26	1379	11.04.2025	KULSHEKAR CHOWKI PUBLIC TAP NEAR DAIRY BUS STAND WARD NO 36 C/O KIRAN J.E, JANARDHAN V.M	36	POTABLE
27	1380	11.04.2025	SHAKTHI NAGAR VARIJA HOUSE KARMIKA COLONY WARD NO 35 C/O KIRAN J.E, PRAVEEN V.M	35	POTABLE
28	1381	11.04.2025	LILLYBAI'S HOUSE NEAR SARIPALLA BUS STOP WARD NO 51 C/O KIRAN J.E, SUNIL V.M	51	POTABLE
29	1382	11.04.2025	KULURU PUMP HOUSE WARD NO 12 C/O DEEKSHA J.E, SUJEER V.M	12	POTABLE
30	1383	11.04.2025	BONDEL TANK WARD NO 14 C/O DEEKSHA J.E, SUJEER V.M	14	POTABLE
31	1384	15.04.2025	PUBLIC TAP NEAR HARIDAS LANE MANNAGUDDA WARD NO 28 C/O KIRAN J.E, SHASHI V.M	28	POTABLE
32	1385	16.04.2025	TARANATHA DOOR NO : 5-209/6 OPPOSITE BHADRAKALI TEMPLE WARD NO 32 C/O MANJUNATH J.E, SAAJI V.M	32	POTABLE
33	1386	16.04.2025	BHADRAKALI TEMPLE NANTHOOR NEAR PADAV SCHOOL WARD NO 32 C/O MANJUNATH J.E, SAAJI V.M	32	POTABLE
34	1388	16.04.2025	K CHANDRASHEKAR RAO BEJAI NEW ROAD DOOR NO 2-10-780/9 5TH CROSS RESORTICA ROAD WARD NO 31 C/O MANJUNATH J.E, BALAKRISHNA V.M	31	POTABLE
35	1389	21.04.2025	UJJODI NEKKARE MAR HEMATH HOUSE VALENCIA KANKANADY C/O BHAVYA J.E, DINAKAR V.M WARD NO 48	48	POTABLE
36	1391	08.05.2025	VAMANJURU MANGALAJYOTHI TANK WARD NO 20 C/O YATHISH J.E, NAGESH V.M	20	POTABLE
37	1392	14.05.2025	CONUPTO DSOUZA DOOR NO 11/100 KARMIKA COLONY SHAKTHINAGARA WARD NO 35 C/O KIRAN J.E JANARDHAN V.M	35	POTABLE
38	1393	14.05.2025	LILLYBAI'S HOUSE NEAR SARIPALLA BUS STOP WARD NO 51 C/O KIRAN J.E, SUNIL V.M	51	POTABLE
39	1394	14.05.2025	SANTHOSH KUMAR SILVER GATE DOOR NO 21-4/6 WARD NO 36 C/O KIRAN J.E, JANARDHAN V.M	36	POTABLE
40	1397	20.05.2025	HLPS, THUMBE		POTABLE
41	1398	20.05.2025	PADIL GLSR		POTABLE
42	1399	20.05.2025	BENDOOR INLET		POTABLE
43	1400	20.05.2025	BENDOOR OUTLET		POTABLE
44	1401	20.05.2025	KARAVALI PUMP HOUSE		POTABLE
45	1402	20.05.2025	MUDA PUMP HOUSE		POTABLE
46	1403	20.05.2025	KOTTARA JALLIGUDDE PUMPHOUSE		POTABLE
47	1404	20.05.2025	PANAMBURU INLET		POTABLE
48	1405	20.05.2025	PANAMBURU OUTLET		POTABLE
49	1406	20.05.2025	KULURU PUMP HOUSE		POTABLE
50	1407	20.05.2025	KAVOOR PUMP HOUSE	**	POTABLE
51	1409	22.05.2025	PUBLIC TAP KACHIKAR COMPOUND WARD NO 41 C/O CHINMAYI J.E MOHAN V.M	41	POTABLE
52	1410	22.05.2025	PUBLIC TAP BEHIND KUDROLI TEMPLE WARD NO 42 C/O CHINMAYI J.E MOHAN V.M	42	POTABLE
53	1411	22.05.2025	SURAJ HOUSE HANUMAN TIMBER ROAD WARD NO 42 C/O CHINMAYI J.E MOHAN V.M	42	POTABLE
54	1412	22.05.2025	SAVITHRI PUTHRAN HOUSE KARNAL GARDEN WARD NO 43 C/O CHINMAYI J.E, MOHAN V.M	43	POTABLE
55	1413	22.05.2025	PUBLIC TAP NEAR MODEEN MOSQUE WARD NO 43 C/O CHINMAYI J.E, MOHAN V.M	43	POTABLE
56	1414	22.05.2025	PUBLIC TAP J.M ROAD WARD NO 44 C/O PADMA J.E, MOHAN V.M	44	POTABLE
57	1415	22.05.2025	SHRI RAM PAINTS GODOWN WARD NO 44 C/O PADMA J.E, MOHAN V.M	44	POTABLE
58	1416	28.05.2025	SHARATH DOOR NO 24-18-1491/2 JAPPU KUDUPADY ROAD WARD NO 55, BHAVYA J.E, SHANTHAPPA V.M	55	POTABLE
59	1417	28.05.2025	SURESH DEVADIGA DOOR NO 239-551 WARD NO 56, CHINMAYI J.E, YASHWANTH V.M	56	POTABLE

60	1418	28.05.2025	MOHINI SATHISH DOOR NO 22-11-1518/13 MULIHITHLU WARD NO 57 , BHAVYA J.E, YASHWANTH V.M	57	POTABLE
61	1419	28.05.2025	NOPIA DOOR NO 22-1-54/48 WARD NO 58 , CHINMAYI J.E, YASHWANTH V.M	58	POTABLE
62	1420	28.05.2025	KAMALAKSHI DOOR NO 25-24-1808 NARAYANA COMPOUND , WARD NO 59, BHAVYA J.E, SHANTHAPPA V.M	59	POTABLE
73	1426	11.06.2025	MERYHILL PUMP HOUSE WARD NO 22 C/O MANJUNATH J.E	22	POTABLE
74	1430	11.06.2025	SC/ ST GIRLS HOSTEL KANNUR CORPORATION DIRECT LINE WATER , WARD NO 52 C/O ASHWIN A.E.E	52	POTABLE
75	1431	11.06.2025	SC/ ST GIRLS HOSTEL KANNUR ,STORAGE WATER , WARD NO 52 C/O ASHWIN A.E.E	52	POTABLE
76	1433	30.06.2025	MUDA PUMP HOUSE	**	POTABLE
77	1434	30.06.2025	PANAMBURU INLET	**	POTABLE
78	1435	30.06.2025	KAVOOR PUMP HOUSE	**	POTABLE
79	1437	22.07.2025	PANAMBURU INLET	**	POTABLE
80	1438	22.07.2025	PANAMBURU OUTLET	**	POTABLE
81	1439	22.07.2025	KULURU PUMP HOUSE	**	POTABLE
82	1440	26.07.2025	PUBLIC TAP NEAR BEHIND GATE OF KUDROLI TEMPLE WARD NO 42 C/O NANDAKISHOR J.EMOHAN V.M	42	POTABLE
83	1441	26.07.2025	HANUMAN TIMBER SURAJ HOUSE WARD NO 42 C/O NANDAKISHOR J.E MOHAN V.M	42	POTABLE
84	1442	26.07.2025	KUDROLI KARNAL GARDEN SAVITHRI PUTHRAN HOUSE WARD NO 43 C/O NANDAKISHOR J.E, MOHAN V.M	43	POTABLE
85	1443	26.07.2025	KUDROLI MOIDEEN PALLI PUBLIC TAP WARD NO 43 C/O NANDAKISHOR J.E , MOHAN V.M	43	POTABLE
86	1444	26.07.2025	PUBLIC TAP JM ROAD WARD NO 44 C/O PADMA J.E ,MOHAN V.M	44	POTABLE
87	1445	26.07.2025	AZIZUDDIN ROAD SHRI RAM PAINTS GO DOWN WARD NO 44 C/O PADMA J.E , MOHAN V.M	44	POTABLE

2023-2024

Sl.No.	SAMPLE NO	DATE	SAMPLE COLLECTION POINT	WARD NO	REPORT NO	REPORT
1	749	03.04.2023	HLPS 1, THUMBE	**	2023-24/19	POTABLE QUALITY
2	750	03.04.2024	HLPS 2, THUMBE	**	2023-24/20	POTABLE QUALITY
3	751	03.04.2023	PADIL GLSR		2023-24/21	POTABLE QUALITY
4	752	03.04.2023	BENDOOR INLET		2023-24/22	POTABLE QUALITY
5	753	03.04.2023	BENDOOR OUTLET		2023-24/23	POTABLE QUALITY
6	754	03.04.2023	KARAVALI PUMPHOUSE		2023-24/24	POTABLE QUALITY
7	757	03.04.2023	PANAMBURU OUTLET		2023-24/27	POTABLE QUALITY
8	760	03.04.2023	KAVOOR PUMPHOUSE		2023-24/30	POTABLE QUALITY
9	761	21.04.2023	MUDA PUMPHOUSE		2023-24/58	POTABLE QUALITY
10	765	21.04.2023	KOTTARA JALLIGUIDDE PUMPHOUSE		2023-24/62	POTABLE QUALITY
11	767	25.04.2023	PANAMBURU OUTLET		2023-24/58	POTABLE QUALITY
12	772	17.05.2023	HLPS 1, THUMBE		2023-24/80	POTABLE QUALITY
13	773	17.05.2023	HLPS 2, THUMBE		2023-24/81	POTABLE QUALITY
14	774	17.05.2023	PADIL GLSR		2023-24/82	POTABLE QUALITY
15	775	17.05.2023	BENDOOR INLET		2023-24/83	POTABLE QUALITY
16	776	17.05.2023	BENDOOR OUTLET		2023-24/84	POTABLE QUALITY
17	780	17.05.2023	PANAMBURU OUTLET		2023-24/88	POTABLE QUALITY
18	791	01.07.2023	PLAMA DIAMOND, BALMATTA WARD NO 38	38	2023-24/38	POTABLE QUALITY
19	792	17.07.2023	HLPS 1		2023-24/98	POTABLE QUALITY
20	793	17.07.2023	HLPS 2, THUMBE		2023-24/99	POTABLE QUALITY
21	794	17.07.2023	PADIL GLSR		2023-24/100	POTABLE QUALITY
22	795	17.07.2023	BENDOOR INLET		2023-24/101	POTABLE QUALITY
23	796	17.07.2023	BENDOOR OUTLET		2023-24/102	POTABLE QUALITY
24	797	17.07.2023	KARAVALI PUMPHOUSE		2023-24/103	POTABLE QUALITY
25	798	17.07.2023	PANAMBURU INLET		2023-24/104	POTABLE QUALITY

26	800	17.07.2023	KULLOOR PUMPHOUSE		2023-24/106	POTABLE QUALITY
27	801	17.07.2023	KAVOOR PUMPHOUSE		2023-24/107	POTABLE QUALITY
28	802	17.07.2023	KOTTARA JALLIGUIDDE PUMPHOUSE		2023-24/108	POTABLE QUALITY
29	806	03.08.2023	9-16-616/1 ABDUL RAHEEM JM ROAD OPPOSITE CRESCENT SCHOOL		2023-24/20	POTABLE QUALITY
30	808	03.08.2023	HLPS 1, THUMBE		2023-24/22	POTABLE QUALITY
31	809	03.08.2023	HLPS 2, THUMBE		2023-24/23	POTABLE QUALITY
32	810	03.08.2023	PADIL GLSR		2023-24/24	POTABLE QUALITY
33	811	03.08.2023	BENDOOD, INLET		2023-24/25	POTABLE QUALITY
34	812	03.08.2023	BENDOOD OUTLET		2023-24/26	POTABLE QUALITY
35	813	03.08.2023	KARAVALI PUMPHOUSE		2023-24/27	POTABLE QUALITY
36	814	03.08.2023	MUDA PUMPHOUSE		2023-24/28	POTABLE QUALITY
37	815	03.08.2023	PANAMBURU INLET		2023-24/29	POTABLE QUALITY
38	816	03.08.2023	PANAMBURU OUTLET		2023-24/30	POTABLE QUALITY
39	817	03.08.2023	KULLOOR PUMPHOUSE		2023-24/31	POTABLE QUALITY
40	818	03.08.2023	KAVOOR PUMPHOUSE		2023-24/32	POTABLE QUALITY
41	819	03.08.2023	KOTTARA JALLIGUDDE PUMPHOUSE		2023-24/33	POTABLE QUALITY
42	820	03.08.2023	JM ROAD OPPOSITE MADINA DARVESH MASJID WARD 44	44	2023-24/34	POTABLE QUALITY
43	822	08.08.2023	KRISHNA PRIYA NEAR K.K TOWER ATTAVARA WARD NO 47	47	2023-24/43	POTABLE QUALITY
44	823	08.08.2023	LAXMI GARDEN GOODSHED DOOR NO: 20-16-1008 WARD NO 45	45	2023-24/44	POTABLE QUALITY
45	825	08.08.2023	BANUMATHI CORPORATOR HOUSE MORGANS GATE WARD NO 58	58	2023-24/46	POTABLE QUALITY
46	834	09.08.2023	KADRI KAI BATAL WARD NO 33	33	2023-24/55	POTABLE QUALITY
47	835	09.08.2023	KADRI SOUTH TEMPLE ROAD WARD NO 33	33	2023-24/56	POTABLE QUALITY
48	836	09.08.2023	SHIVABAGH WARD BEDAGI CONVENT ROAD WARD NO 34	34	2023-24/57	POTABLE QUALITY
49	837	09.08.2023	SHIVABAGH WARD KADRI PUMP HOUSE ROAD WARD NO 34	34	2023-24/58	POTABLE QUALITY

50	838	09.08.2023	MAROLI BIKARNAKATTE BAJJODI, NEAR BAJJODI CHURCH WARD NO 37	37	2023-24/59	POTABLE QUALITY
51	839	09.08.2023	MAROLI RAMANJANEYA VYAYAMA SCHOOL WARD NO 37	37	2023-24/60	POTABLE QUALITY
52	840	09.08.2023	KADRI CIRCUIT HOUSE WARD NO 30	30	2023-24/61	POTABLE QUALITY
53	841	09.08.2023	NANTHOOR PADAU TANK WARD NO 32	32	2023-24/62	POTABLE QUALITY
54	850	14.08.2023	SHAKTHINAGARA TANK SHAKTHINAGRA KANDETTU WARD NO 21	21	2023-24/109	POTABLE QUALITY
55	852	14.08.2023	KARMIKA COLONY TANK KULSHEKARA WARD NO 35	35	2023-24/111	POTABLE QUALITY
56	853	14.08.2023	9-9-463 ISMAIL KOTEKAR COMPOUND WARD NO 44	44	2023-24/112	POTABLE QUALITY
57	855	14.08.2023	10-5--170 LATHIF AKBAR ALI COMPOUND KASAYI GALLI WARD NO 41	41	2023-24/114	POTABLE QUALITY
58	856	14.08.2023	11-11-1102 HARISH H U COMPOUND T T ROAD WARD NO 41	41	2023-24/115	POTABLE QUALITY
59	857	14.08.2023	8-14-1293 RAVINDRA SUVARNA KUDROLI WARD NO 43	43	2023-24/116	POTABLE QUALITY
60	858	14.08.2023	5-9--975/2 KAMATH HANUMAN TIMBER ALAKE ROAD WARD NO 42	42	2023-24/117	POTABLE QUALITY
61	859	14.08.2023	CLARIFIED WATER SAMPLE BENDOOR, INLET		2023-24/118	POTABLE QUALITY
62	860	16.08.2023	KANTHARAJA LANE MANNAGUDDA , WARD NO 28	28	2023-24/119	POTABLE QUALITY
63	864 (821)	17.08.2023	NEAR PANDESHWARA KATTE WARD NO 46	46	2023-24/123	POTABLE QUALITY
64	865 (824)	17.08.2023	ANANTHA PADMA RAJ DOOR NO: 23-9-603/6 MANGALANAGARA MANGALADEVI WARD NO 56	56	2023-24/124	POTABLE QUALITY
65	869	17.08.2023	KULUR PUMP HOUSE WARD NO 12	12	2023-24/128	POTABLE QUALITY
66	870	17.08.2023	PRITHVI LAYOUT KULUR WARD NO 12	12	2023-24/129	POTABLE QUALITY
67	875	25.08.2023	INDUSTRY AREA WARD NO 10	10	2023-24/164	POTABLE QUALITY
68	877	25.08.2023	HOTEL MAHI WARD NO 9	9	2023-24/166	POTABLE QUALITY
69	881	25.08.2023	ULLAS NAGARA WARD NO 10	10	2023-24/170	POTABLE QUALITY
70	882	28.08.2023	SISTER COMPOUND TANK WARD NO 51	51	2023-24/21	POTABLE QUALITY

71	883	28.08.2023	SISTER'S COMPOUND CHARLES HOME DOOR NO.7-63/20 SARIPALLA ALAPE NORTH WARD NO 51	51	2023-24/22	POTABLE QUALITY
72	887	09.09.2023	MARYHILL PUMP HOUSE WARD NUMBER 22	22	2023-24/46	POTABLE QUALITY
73	889	13.09.2023	HLPS , THUMBE	**	2023-24/48	POTABLE QUALITY
74	890	13.09.2023	PADIL GLSR		2023-24/49	POTABLE QUALITY
75	891	13.09.2023	BENDDOOR OUTLET		2023-24/50	POTABLE QUALITY
76	892	13.09.2023	BENDDOOR INLET		2023-24/51	POTABLE QUALITY
77	893	13.09.2023	KARAVALI PUMPHOUSE		2023-24/52	POTABLE QUALITY
78	894	13.09.2023	MUDA PUMPHOUSE		2023-24/53	POTABLE QUALITY
79	895	13.09.2023	PANAMBURU INLET		2023-24/54	POTABLE QUALITY
80	896	13.09.2023	PANAMBURU OUTLET		2023-24/55	POTABLE QUALITY
81	897	13.09.2023	KULLOOR PUMPHOUSE		2023-24/56	POTABLE QUALITY
82	898	13.09.2023	KAVOOR PUMPHOUSE		2023-24/57	POTABLE QUALITY
83	899	13.09.2023	KOTTARA JALLIGUDDE PUMPHOUSE		2023-24/58	POTABLE QUALITY
84	900	13.09.2023	MARYHILL PUMP HOUSE WARD NUMBER 22	22	2023-24/59	POTABLE QUALITY
85	901	15.09.2023	SANDHYA DOOR NUMBER 21-P- IV 85/3 BAGATH SINGH ROAD HOIGE BAZAR WARD NO :57	57	2023-24/60	POTABLE QUALITY
86	903	03.10.2023	BASAVARAJ P MARATE JANANI NILAYA BHARATH CAFÉ BLOCK 1 KAIKAMBA		2023-24/13	POTABLE QUALITY
87	906	03.10.2023	ASHRAF , DKZP HIGHER PRIMARY SCHOOL ROAD DOOR NO 78 , 8TH BLOCK WARD NO 5	5	2023-24/16	POTABLE QUALITY
88	907	03.10.2023	PURANDARI NIVAS DOOR NO 2-64/2 GIRISH GUDDE KOPPALA WARD NO 7	7	2023-24/17	POTABLE QUALITY
89	911	06.10.2023	VASUDEVA PAI DOOR NO 10-24/2 WARD NO 1	1	2023-24/54	POTABLE QUALITY
90	913	09.10.2023	HLPS , THUMBE	**	2023-24/56	POTABLE QUALITY
91	914	09.10.2023	BENDDOOR INLET		2023-24/57	POTABLE QUALITY
92	915	09.10.2023	BENDDOOR OUTLET		2023-24/58	POTABLE QUALITY
93	916	09.10.2023	KARAVALI PUMPHOUSE		2023-24/59	POTABLE QUALITY
94	917	09.10.2023	MUDA PUMPHOUSE		2023-24/60	POTABLE QUALITY

95	918	09.10.2023	PANAMBURU INLET		2023-24/61	POTABLE QUALITY
96	919	09.10.2023	PANAMBURU OUTLET		2023-24/62	POTABLE QUALITY
97	920	09.10.2023	KULLOOR PUMPHOUSE		2023-24/63	POTABLE QUALITY
98	921	09.10.2023	KAVOOR PUMPHOUSE		2023-24/64	POTABLE QUALITY
99	922	09.10.2023	KOTTARA JALLIGUDDE PUMPHOUSE		2023-24/65	POTABLE QUALITY
100	923	09.10.2023	PADIL GLSR		2023-24/66	POTABLE QUALITY
101	929	13.10.2023	CIRCUIT HOUSE TANK WATER WARD NUMBER 30	30	2023-24/80	POTABLE QUALITY
102	932	13.11.2023	HLPS , THUMBE	**	2023-24/68	POTABLE QUALITY
103	933	13.11.2023	PADIL GLSR		2023-24/69	POTABLE QUALITY
104	934	13.11.2023	BENDOOR INLET		2023-24/70	POTABLE QUALITY
105	935	13.11.2023	BENDOOR OUTLET		2023-24/71	POTABLE QUALITY
106	936	13.11.2023	KARAVALI PUMPHOUSE		2023-24/72	POTABLE QUALITY
107	937	13.11.2023	MUDA PUMPHOUSE		2023-24/73	POTABLE QUALITY
108	938	13.11.2023	PANAMBURU INLET		2023-24/74	POTABLE QUALITY
109	939	13.11.2023	PANAMBURU OUTLET		2023-24/75	POTABLE QUALITY
110	940	13.11.2023	KOTTARA JALLIGUDDE PUMPHOUSE		2023-24/76	POTABLE QUALITY
111	941	13.11.2023	KULLOOR PUMPHOUSE		2023-24/77	POTABLE QUALITY
112	942	13.11.2023	KAVOOR PUMPHOUSE		2023-24/78	POTABLE QUALITY
113	943	20.11.2023	K2 APARTMENT WARD NO 46 PANDESHWARA C/O Mithun J.E	46	2023-24/128	POTABLE QUALITY
114	957	11.01.2024	HLPS , THUMBE	**	2023-24/47	POTABLE QUALITY
115	958	11.01.2024	PADIL GLSR		2023-24/48	POTABLE QUALITY
116	959	11.01.2024	BENDOOR INLET		2023-24/49	POTABLE QUALITY
117	960	11.01.2024	BENDOOR OUTLET		2023-24/50	POTABLE QUALITY
118	961	11.01.2024	KARAVALI PUMPHOUSE		2023-24/51	POTABLE QUALITY
119	962	11.01.2024	MUDA PUMPHOUSE		2023-24/52	POTABLE QUALITY
120	963	11.01.2024	KOTTARA JALLIGUDDE PUMPHOUSE		2023-24/53	POTABLE QUALITY
121	964	11.01.2024	PANAMBURU INLET		2023-24/54	POTABLE QUALITY
122	965	11.01.2024	PANAMBURU OUTLET		2023-24/55	POTABLE QUALITY

123	966	11.01.2024	KULLOOR PUMPHOUSE		2023-24/56	POTABLE QUALITY
124	967	11.01.2024	KAVOOR PUMPHOUSE		2023-24/57	POTABLE QUALITY
125	971	16.01.2024	CIRCUIT HOUSE TANK WARD NUMBER 30 C/O SAHANA J.E	30	2023-24/66	POTABLE QUALITY
	972	17.01.2024	KATIPALLA NORTH 8TH BLOCK DKZP SCHOOL AREA 6TH BLOCK TANK WARD NO 5 C/O VINOD KUMAR J.E	5	2023-24/67	POTABLE QUALITY
126						
	973	17.01.2024	IDYA EAST SIRIGALA BEEDU KULAI PUMP HOUSE LINE WATER WARD NO 6 C/O VINOD KUMAR J.E	6	2023-24/68	POTABLE QUALITY
127						
	974	17.01.2024	HOSABETTU KODIKERE MATEGURI BALA TANK WARD NO 8 C/O VINOD KUMAR J.E	8	2023-25/69	POTABLE QUALITY
128						
129	978	05.02.2024	KARAVALI PUMPHOUSE		2023-24/22	POTABLE QUALITY
130	983	08.02.2024	MERYHILL PUMP HOUSE C/O ASHWIN		2023-24/29	POTABLE QUALITY
131	986	12.02.2024	HLPS , THUMBE	**	2023-24/105	POTABLE QUALITY
132	987	12.02.2024	PADIL GLSR		2023-24/106	POTABLE QUALITY
133	988	12.02.2024	BENDOOR INLET		2023-24/107	POTABLE QUALITY
134	989	12.02.2024	BENDOOR OUTLET		2023-24/108	POTABLE QUALITY
135	990	12.02.2024	KARAVALI PUMPHOUSE		2023-24/109	POTABLE QUALITY
136	991	12.02.2024	MUDA PUMPHOUSE		2023-24/110	POTABLE QUALITY
137	992	12.02.2024	KOTTARA JALLIGUDDE PUMPHOUSE		2023-24/111	POTABLE QUALITY
138	993	12.02.2024	PANAMBURU INLET		2023-24/113	POTABLE QUALITY
139	994	12.02.2024	PANAMBURU OUTLET		2023-24/114	POTABLE QUALITY
140	995	12.02.2024	KULLOOR PUMPHOUSE		2023-24/115	POTABLE QUALITY
141	996	12.02.2024	KAVOOR PUMPHOUSE		2023-24/116	POTABLE QUALITY
142	997	12.02.2024	BONDEL TANK WATER WARD NO 15	15	2023-24/117	POTABLE QUALITY
143	998	12.02.2024	MERYHILL PUMP HOUSE	30	2023-24/118	POTABLE QUALITY
144	999	15.02.2024	CIRCUITHOUSE TANK WATER C/O SAHANA J.E		2023-24/119(A)	POTABLE QUALITY
145	1003	04.03.2024	HLPS , THUMBE		2023-24/24	POTABLE QUALITY
146	1004	04.03.2024	GLSR PADIL		2023-24/25	POTABLE QUALITY
147	1005	04.03.2024	BENDOOR INLET		2023-24/26	POTABLE QUALITY
148	1006	04.03.2024	BENDOOR OUTLET		2023-24/27	POTABLE QUALITY

[illegible]

2022- 2023

Sl.No	SAMPLE NO	DATE	SAMPLE COLLECTION POINT	WARD NO	REPORT NO	REPORT
1	557	04.04.2022	TAPOVAN TOWERS ALAKE	42	2022-23/35	POTABLE QUALITY
2	560	04.04.2022	BENDOOR PLANT OUTLET	**	2022-23/38	POTABLE QUALITY
3	561	07.04.2022	LOKAYYA SHETTY KUSUMA VIHAR VADIRAJA NAGAR	42	2022-23/64	POTABLE QUALITY
4	563	07.04.2022	CHANDRAHASA SHETTY SRI NITHYANANDA KKRIPA BHAGAVATHI KRUPA 1ST MAIN MANNAGUDDA	42	2022-23/66	POTABLE QUALITY
5	565	07.04.2022	PANAMBURU PAMPHOUSE OUTLET	**	2022-23/68	POTABLE QUALITY
6	571	07.04.2022	PADIL GLSR	**	2022-23/74	POTABLE QUALITY
7	572	13.04.2022	KANNURU MAINLINE		2022-23/81	POTABLE QUALITY
8	573	13.04.2022	BENDOOR PLANT INLET	**	2022-23/82	POTABLE QUALITY
9	577	13.04.2022	WINMAN NH66 KOTTARA CHAOWKI	17	2022-23/86	POTABLE QUALITY
10	583	13.06.2022	HLPS 1 THUMBE	**	2022-23/31	POTABLE QUALITY
11	584	13.06.2022	HLPS 2 THUMBE	**	2022-23/32	POTABLE QUALITY
12	586	13.06.2022	PADIL GLSR	**	2022-23/34	POTABLE QUALITY
13	587	13.06.2022	BENDOOR INLET	**	2022-23/35	POTABLE QUALITY
14	588	13.06.2022	BENDOOR OUTLET	**	2022-23/36	POTABLE QUALITY
15	589	13.06.2022	MARRYHILL PUMPHOUSE	**	2022-23/37	POTABLE QUALITY
16	590	13.06.2022	KULURU PUMPHOUSE	**	2022-23/38	POTABLE QUALITY
17	591	13.06.2022	PANAMBURU INLET	**	2022-23/39	POTABLE QUALITY
18	592	13.06.2022	JALLIGUDDE PUMPHOUSE	**	2022-23/40	POTABLE QUALITY
19	593	13.06.2022	WINMAN NH66 KOTTARA CHAOWKI	17	2022-23/41	POTABLE QUALITY
20	594	21.06.2022	Winezone Mohandas lane Attavara katte	40	2022-23/64	POTABLE QUALITY

21	595	21.06.2022	Arvind D no 22-2-231/2 Tailor road Mulihithlu	58	2022-23/65	POTABLE QUALITY
22	596	21.06.2022	Kaprigudda Opp KMC HOSTEL ATTAVARA	47	2022-23/66	POTABLE QUALITY
23	597	21.06.2022	Loretto Felcy tauro Mulihithlu junction	57	2022-23/67	POTABLE QUALITY
24	598	21.06.2022	Adrois compound Kudpady jeppu	55	2022-23/68	POTABLE QUALITY
25	599	21.06.2022	Vandana praveen 22-3-385/1 Gujjerejere	58	2022-23/69	POTABLE QUALITY
26	600	21.06.2022	Gopaldas 25-25-1936 Kudpady road Jeppu	59	2022-23/70	POTABLE QUALITY
27	601		Sadguru nivasa Sooterpete Main road	59	2022-23/71	POTABLE QUALITY
28	603	28.07.2022	HLPS 1, THUMBE	**	2022-23/7	POTABLE QUALITY
29	604	28.07.2022	HLPS 2, THUMBE	**	2022-23/8	POTABLE QUALITY
30	605	28.07.2022	PADIL GLSR	**	2022-23/9	POTABLE QUALITY
31	606	28.07.2022	BENDOOR PUMPHOUSE INLET	**	2022-23/10	POTABLE QUALITY
32	607	28.07.2022	BENDOOR PUMPHOUSE OUTLET	**	2022-23/11	POTABLE QUALITY
33	612	28.07.2022	PANAMBURU PUMPHOUSE OUTLET	**	2022-23/16	POTABLE QUALITY
34	614	28.07.2022	PACHANADY PUMPHOUSE	**	2022-23/18	POTABLE QUALITY
35	615	12.08.2022	KAVOOR PUMPHOUSE	15	2022-23/44	POTABLE QUALITY
36	616	12.08.2022	DURGA NIVAS 2-4, KULLOOR	12	2022-23/45	POTABLE QUALITY
37	617	12.08.2022	KUNJATHBAIL OHT		2022-23/46	POTABLE QUALITY
38	618	12.08.2022	CORPORATER OFFICE, VAMANJURU JUNCTION	20	2022-23/47	POTABLE QUALITY
39	622	24.08.2022	PUBLIC TAP BOLOOR		2022-23/121	POTABLE QUALITY
40	623	24.08.2022	BOLOOR		2022-23/122	POTABLE QUALITY
41	624	09.09.2022	HLPS 1	**	2022-23/22	POTABLE QUALITY
42	625	09.09.2022	HLPS 2	**	2022-23/23	POTABLE QUALITY

43	626	09.09.2022	GLSR PADIL	**	2022-23/24	POTABLE QUALITY
44	627	09.09.2022	BENDOOR INLET	**	2022-23/25	POTABLE QUALITY
45	628	09.09.2022	BENDOOR OUTLET	**	2022-23/26	POTABLE QUALITY
46	629	09.09.2022	KARAVALI PUMPHOUSE	**	2022-23/27	POTABLE QUALITY
47	630	09.09.2022	MUDA PUMPHOUSE	**	2022-23/28	POTABLE QUALITY
48	631	09.09.2022	PANAMBURU OUTLET	**	2022-23/29	POTABLE QUALITY
49	634	09.09.2022	KOTTARA JALLIGUDDE PUMPHOUSE	**	2022-23/32	POTABLE QUALITY
50	640	18.10.2022	BENDOOR PUMPHOUSE	**	2022-23/22	POTABLE QUALITY
51	641	18.10.2022	TREATED WATER HLPS 2	**	2022-23/23	POTABLE QUALITY
52	643	18.10.2022	MUDA PUMPHOUSE	**	2022-23/25	POTABLE QUALITY
53	644	18.10.2022	PANAMBURU PUMPHOUSE INLET	**	2022-23/26	POTABLE QUALITY
54	645	18.10.2022	PANAMBURU PUMPHOUSE OUTLET	*	2022-23/27	POTABLE QUALITY
55	646	18.10.2022	KULLOOR PUMPHOUSE	**	2022-23/28	POTABLE QUALITY
56	647	18.10.2022	KAVOOR PUMPHOUSE	**	2022-23/29	POTABLE QUALITY
57	648	18.10.2022	PADIL GLSR	**	2022-23/30	POTABLE QUALITY
58	650	03.11.2022	SHIVA SHANTH SHANTHA 28-2340 KADRI TEMPLE ROAD	33	2022-23/18	POTABLE QUALITY
59	651	03.11.2022	KADARIKA HOUSE KADRI NEW ROAD BEJAI	32	2022-23/19	POTABLE QUALITY
60	652	03.11.2022	BALAKRISHNA 4-3332 SOORYA GANESH RAO LANE NEAR LOYELA HOSTEL KODIALBAIL 3	30	2022-23/20	POTABLE QUALITY
61	653	03.11.2022	AFIZULLA 5-6-396 PVS KALAKUNJ ALAKE KAMBLA	29	2022-23/21	POTABLE QUALITY
62	654	03.11.2022	D ANANTH PAI 13-13-942 DONGEREKERI	42	2022-23/22	POTABLE QUALITY
63	655	03.11.2022	PREMA PAI 13-13-942 VT ROAD TANK COLONY NEAR SHRINIVAS VEDA PATA SHALE	41	2022-23/23	POTABLE QUALITY
64	656	03.11.2022	SURESH S L MATHAIS ROAD ISLAND FALNIR	47	2022-23/24	POTABLE QUALITY

65	657	03.11.2022	PRASHANTH SHASTHRI 18-4-193/5 SANTHEPTHI OPP : CENTRAL REVENUE BUILDING ATTAVARA	40	2022-23/25	POTABLE QUALITY
66	658	03.11.2022	SAI PRABHU ASHOK PRABHU 14-3-264-264 A DON BOSCO HALL ROAD FALNIR	38	2022-23/26	POTABLE QUALITY
67	660	15.11.2022	HLPS 1 THUMBE	**	2022-23/95	POTABLE QUALITY
68	661	15.11.2022	HLPS 2 THUMBE	**	2022-23/96	POTABLE QUALITY
69	662	15.11.2022	BENDOOR INLET	**	2022-23/97	POTABLE QUALITY
70	663	15.11.2022	BENDOOR OUTLET	**	2022-23/98	POTABLE QUALITY
71	664	15.11.2022	KARAVALI PUMPHOUSE	**	2022-23/99	POTABLE QUALITY
72	668	15.11.2022	KOTTARA JALLIGUDDE PUMPHOUSE	**	2022-23/103	POTABLE QUALITY
73	669	15.11.2022	PADIL GLSR	**	2022-23/104	POTABLE QUALITY
74	671	15.11.2022	SHRIKALA PRABHU PERLAGUR I	18	2022-23/106	POTABLE QUALITY
75	672	24.11.2022	HLPS 1	**	2022-23/8	POTABLE QUALITY
76	673	24.11.2022	BENDOOR INLET	**	2022-23/9	POTABLE QUALITY
77	674	24.11.2022	BENDOOR PUMPHOUSE OUTLET	**	2022-23/10	POTABLE QUALITY
78	677	24.11.2022	KULLOOR PUMPHOUSE	**	2022-23/13	POTABLE QUALITY
79	682	06.12.2022	MUDA PUMPHOUSE : INLET SAMPLE		2022-23/21	POTABLE QUALITY
80	683	06.12.2022	MUDA PUMPHOUSE : OUTLET SAMPLE	**	2022-23/22	POTABLE QUALITY
81	684	06.12.2022	KOTTARA JALLIGUDDE PUMPHOUSE INLET SAMPLE	**	2022-23/23	POTABLE QUALITY
82	685	06.12.2022	KOTTARA JALLIGUDDE PUMPHOUSE OUTLET SAMPLE	**	2022-23/24	POTABLE QUALITY
83	686	06.12.2022	KULLOOR PUMPHOUSE INLET SAMPLE	**	2022-23/25	POTABLE QUALITY
84	687	06.12.2022	KULLOOR PUMPHOUSE OUTLET SAMPLE	**	2022-23/26	POTABLE QUALITY
85	689	06.12.2022	KAVOOR PUMPHOUSE INLET SAMPLE	**	2022-23/28	POTABLE QUALITY
86	690	06.12.2022	PANAMBURU PUMPHOUSE INLET	**	2022-23/29	POTABLE QUALITY
87	691	06.12.2022	BENDOOR PUMPHOUSE INLET SAMPLE	**	2022-23/30	POTABLE QUALITY


88	695	07.01.2023	HLPS 1, THUMBE	**	2022-23/18	POTABLE QUALITY
89	696	07.01.2023	HLPS 2, THUMBE	**	2022-23/19	POTABLE QUALITY
90	697	07.01.2023	GLSR PADIL	**	2022-23/20	POTABLE QUALITY
91	698	07.01.2023	BENDOOD, INLET	**	2022-23/21	POTABLE QUALITY
92	699	07.01.2023	BENDOOD OUTLET	**	2022-23/22	POTABLE QUALITY
93	700	07.01.2023	KARAVALI PUMPHOUSE	**	2022-23/23	POTABLE QUALITY
94	701	07.01.2023	MUDA PUMPHOUSE	**	2022-23/24	POTABLE QUALITY
95	702	07.01.2023	KOTTARA JALLIGUIDDE PUMPHOUSE	**	2022-23/25	POTABLE QUALITY
96	703	07.01.2023	PANAMBURU INLET	**	2022-23/26	POTABLE QUALITY
97	704	07.01.2023	PANAMBURU OUTLET	**	2022-23/27	POTABLE QUALITY
98	705	07.01.2023	KULLOOR PUMPHOUSE	**	2022-23/28	POTABLE QUALITY
99	706	07.01.2023	KAVOOR PUMPHOUSE	**	2022-23/29	POTABLE QUALITY
100	712	10.02.2023	CITY HOSPITAL CAMPUS SHAKTHINAGARA HOSTEL 2, SEQUENCE NO 49392		2022-23/63	POTABLE QUALITY
101	713	10.02.2023	CITY HOSPITAL CAMPUS SHAKTHINAGARA HOSTEL 2, SEQUENCE NO 80989		2022-23/64	POTABLE QUALITY
102	714	10.02.2023	CITY HOSPITAL CAMPUS SHAKTHINAGARA HOSTEL 2, SEQUENCE NO 60661		2022-23/65	POTABLE QUALITY
103	716	10.02.2023	CITY HOSPITAL CAMPUS SHAKTHINAGARA HOSTEL SEQUENCE NO 80175		2022-23/67	POTABLE QUALITY
104	717	10.02.2023	CITY HOSPITAL CAMPUS SHAKTHINAGARA HOSTEL SEQUENCE NO 49259		2022-23/68	POTABLE QUALITY
105	719	10.02.2023	ANNA MARIA MANOHARA NIVAS, 10-146, MANJADKA, SHAKTHINAGARA		2022-23/70	POTABLE QUALITY
106	720	10.02.2023	K S AMIN 16-29 PADAVU SHAKTHINAGARA		2022-23/71	POTABLE QUALITY
107	721	10.02.2023	SHAKTHINAGARA OHT SAMPLE		2022-23/72	POTABLE QUALITY
108	722	14.02.2023	SHAKTHI RESIDENTIAL SCHOOL, SHAKTHINAGARA		2022-23/73	POTABLE QUALITY
109	723	14.02.2023	PADIL GLSR	**	2022-23/74	POTABLE QUALITY

110	728	01.03.2023	HEMAVATHI BHAGATH SINGH ROAD D.NO : 21-1-16 9880845876	57	2022-23/79	POTABLE QUALITY
111	732	08.03.2023	RAW WATER SAMPLE LLPS THUMBE		2022-23/96	POTABLE QUALITY
112	733	08.03.2023	HLPS 1, THUMBE	**	2022-23/97	POTABLE QUALITY
113	734	08.03.2023	HLPS 2, THUMBE	**	2022-23/98	POTABLE QUALITY
114	735	08.03.2023	GLSR PADIL	**	2022-23/99	POTABLE QUALITY
115	736	08.03.2023	BENDOOR, INLET	**	2022-23/100	POTABLE QUALITY
116	737	08.03.2023	BENDOOR OUTLET	**	2022-23/101	POTABLE QUALITY
117	738	08.03.2023	KARAVALI PUMPHOUSE	**	2022-23/102	POTABLE QUALITY
118	739	08.03.2023	MUDA PUMPHOUSE	**	2022-23/103	POTABLE QUALITY
119	740	08.03.2023	KOTTARA JALLIGUIDDE PUMPHOUSE	**	2022-23/104	POTABLE QUALITY
120	741	08.03.2023	PANAMBURU INLET	**	2022-23/105	POTABLE QUALITY
121	742	08.03.2023	PANAMBURU OUTLET	**	2022-23/106	POTABLE QUALITY
122	744	08.03.2023	KAVOOR PUMPHOUSE	**	2022-23/108	POTABLE QUALITY
123	745	10.03.2023	KISHORE BOLAR, PERI ROAD HOUSE D.NO : 21-6- 943 M: 8951949492		2022-23/109	POTABLE QUALITY
124	746	10.03.2023	RAMA POOJARY HOUSE BOLAR PERI ROAD HOUSE D NO 22-9- 1355 M 8453797861		2022-23/110	POTABLE QUALITY

ಛನುಬಂಢ -3.

ANNEXUR-1

Sr. No.	ULB Name	ULB Code	UWTP ID	UWTP Name/Location	Incentive in Crores	Eligible incentive in 1st installment in crores (70%)	DPR Status
1	Mangalore	803181	KA-803181-001	STP Kavoor	1	0.70	Under Preparation
2	Mangalore	803181	KA-803181-002	STP Bajal	1	0.70	
3	Mangalore	803181	KA-803181-003	STP Pachanday	0.75	0.53	
4	Mangalore	803181	KA-803181-004	STP Surathkal	1	0.70	
				Total	3.75	2.625	


 ಸಹಾಯಕ ನಿರ್ದೇಶಕರು (ಅಭಿವೃದ್ಧಿ)
 ಪೌರಾಡಳಿತ ನಿರ್ದೇಶನಾಲಯ
 ಬೆಂಗಳೂರು